WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94181
Permit No.
Basin 162

NOTICE OF INTENT NO. 26482

1. OWNER Harvick
MAILING ADDRESS 791 W. Huracan
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
791 W. Huracan

2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 20S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources | 40-392-04 Parcel No. | Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	16	16
grey loam		16	21	5
brown clay		21	43	22
grey loam		43	52	9
brown loam		52	77	25
brown caleche	x	77	79	2
See next line	x	79	93	14
brown loam with caleche strings				
brown loam	x	93	148	55
See next line	x	148	200	52
brown loam with caleche strings				

Date started 7/5/04, 19__
Date completed 7/5/04, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 160 feet to 200 feet

9. WATER LEVEL

Static water level 77 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor

Address 5801 S. Homestead
Contractor

Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date 8.12.04

DCNR/DWR RECEIVED AUG 3 1 2004 LAS VEGAS OFFICE