COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94200
Permit No.
Basin 107

NOTICE OF INTENT NO. 49774

1. OWNER ROB STINNETT CONSTRUCTION
MAILING ADDRESS P.O. BOX 11
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION #35 COLONY ESTATES DR
WELLINGTON NV, 894443

2. LOCATION NW SE ¼ SE ¼ Sec 34 T 11 N R 23 E LYON County

PERMIT NO. (Issued by Water Resources) 09/141/05 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	4	4
HARDPAN CLAY		4	8	4
COURSE SANDS		8	13	5
BROWN CLAY		13	68	55
SILTY SANDS		68	95	27
BROWN CLAY		95	160	65
FRACTURED GRAVELS DG SANDS	XXX	160	205	45
deepened by log 122695				

Date started 8/24, 20 04
Date completed 8/25, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	205 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	25
6 5/8sdr21	4.306	.216	25	205

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 185 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 205 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 8/27/04

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429