WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

3 wells

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 94215
Permit No.
Basin 212

NOTICE OF INTENT NO. 26208

1. OWNER Secor International
MAILING ADDRESS 5755 S. Sandhill Road St. A
Las Vegas, NV 89120

ADDRESS AT WELL LOCATION 7-Eleven
3001 S. Valley View Blvd
Las Vegas, NV

2. LOCATION NE ¼ NE ¼ Sec. 7 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | 162-077-02-004 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Sand w/ Gravel | | 0 | 6 | 6 |
| Cemented sands + gravel | | 6 | 9 | 3 |
| Silty Sand w/ clay | | 9 | 14 | 5 |
| Cemented sands + gravel | | 14 | 16 | 2 |
| Silty Sand w/ clay | | 16 | 22 | 6 |
| Clay | | 22 | 30 | 8 |

DCNR/DWR
RECEIVED
AUG 12 2004
LAS VEGAS OFFICE

Date started June 2, 2004
Date completed June 3, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 30 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | Sch 40 | PVC | 0 | 10 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory Slotted
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 30 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 1421 S. 39th Ave (Contractor)
Phoenix, AZ 85009
Nevada contractor's license number issued by the State Contractor's Board 12852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057
Signed (By driller performing actual drilling on site or contractor)
Date July 1, 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627