

5 wells

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 94237  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27102

1. OWNER Conoco Phillips Co. ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 1230 W WASHINGTON #212 2390 N DECATUR BLVD  
TEMPE, AZ 85281 LAS VEGAS, NV  
2. LOCATION NW 1/4 NW 1/4 Sec. 19 T. 20 NSR C1 E CLARK County  
PERMIT NO. \_\_\_\_\_ Parcel No. 139-19-101-001 Subdivision Name \_\_\_\_\_  
Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TYPE II fill</u>		<u>0.0</u>	<u>2.0</u>	<u>2.0</u>
<u>SANDY BROWN CLAY</u>		<u>2.0</u>	<u>9.0</u>	<u>7.0</u>
<u>CLAY</u>		<u>9.0</u>	<u>13.0</u>	<u>4.0</u>
<u>SANDY BROWN CLAY</u>		<u>13.0</u>	<u>18.0</u>	<u>5.0</u>
<u>SANDY CLAY w GRAVEL</u>		<u>18.0</u>	<u>25.0</u>	<u>7.0</u>
<u>HARD BROWN CLAY</u>		<u>25.0</u>	<u>33.0</u>	<u>8.0</u>

8. WELL CONSTRUCTION  
Depth Drilled 33.0 Feet Depth Cased 33.0 Feet  
HOLE DIAMETER (BIT SIZE)  
From 9.0 Inches To 0.0 Feet 33.0 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>sch 40</u>	<u>0.0</u>	<u>18.0</u>

Perforations:  
Type perforation Machine Slotted  
Size perforation .020  
From 33.0 feet to 18.0 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 12.0  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 16.0 feet to 33.0 feet

9. WATER LEVEL  
Static water level 19.0 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 9/25 2004  
Date completed 9/27 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WIDE EXPLORATION & WELLS Contractor  
Address 570 CANTHIAN WAY Contractor  
N. LAS VEGAS, NV 89030  
Nevada contractor's license number issued by the State Contractor's Board 0012852  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2702  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 10/12/04