

OFFICE USE ONLY  
Log No. 992248  
Permit No. 212  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27103

1. OWNER George Phillips Co.  
MAILING ADDRESS: 1230 WASHINGTON #212 TEMPE, AZ 85281  
ADDRESS AT WELL LOCATION: 5700 VEGAS DR LAS VEGAS, NV  
2. LOCATION: Sec 1/4 SE 1/4 Sec 24 T 20S N3R 60E E CLARK County  
PERMIT NO. 150-24-801-019 Parcel No. 150-24-801-019 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4.  Domestic  Municipal/Industrial  Irrigation  Test  Stock  Cable  Rotary  RVC  
 Monitor  Air  Other KA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1 1/2" - 2" FILL</u>		<u>0.0</u>	<u>2.5</u>	<u>2.5</u>
<u>SANDY CLAY w/ COBBLES</u>		<u>2.5</u>	<u>4.0</u>	<u>1.5</u>
<u>CAVILINE</u>		<u>4.0</u>	<u>6.0</u>	<u>2.0</u>
<u>5 1/2" SAND w/ gravel</u>		<u>6.0</u>	<u>18.0</u>	<u>12.0</u>
<u>Hard Brown clay</u>		<u>18.0</u>	<u>27.0</u>	<u>9.0</u>
		<u>27.0</u>	<u>33.0</u>	<u>6.0</u>

8. WELL CONSTRUCTION  
Depth Drilled: 33.0 Feet Depth Cased: 33.0 Feet  
HOLE DIAMETER (BIT SIZE)  
From 9.0 Inches To 9.0 Feet  
From 9.0 Inches To 33.0 Feet  
From 9.0 Inches To 33.0 Feet  
From 9.0 Inches To 33.0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (feet)	To (feet)
<u>4.250</u>		<u>5/16</u>	<u>0.0</u>	<u>18.0</u>

Perforations: Mechanical Slotted  
Type perforation 0.020  
Size perforation 33.0 feet to 18.0 feet  
From 33.0 feet to 18.0 feet  
From 18.0 feet to 18.0 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal: 12.0  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 18.0 feet to 33.0 feet

9. WATER LEVEL  
Static water level: 20.0 feet below land surface  
Artesian flow: 20.0 G.P.M. P.S.I.  
Water temperature: 78 °F Quality

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WOC EXPLORATION + WELLS Contractor  
Address: 5700 GENTIAN WAY  
N. LAS VEGAS, NV 89030

7. WELL TEST DATA  
TEST METHOD:  Bailor  Pump  Air Lift  
G.P.M. Draw Down (feet Below Static) Time (Hours)  
Date started: 9/28 2004  
Date completed: 10/3 2004