

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. **99232B**  
Permit No. **212**  
Basin. **212**

7 WELLS

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. **27103**

1. OWNER George Phillips Co.  
MAILING ADDRESS 5700 WASHINGTON #212 TEMPE AZ 85224  
LAS VEGAS NV  
2. LOCATION 500 W. 5E 1/4 Sec. 24 T. 20S N. 8R. 60E CLAYEL County  
Issued by Water Resources 158-24-801-019 Parcel No. 5700 WASHINGTON  
Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Municipal/Industrial  
 Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other KA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
199E II FILL		0.0	2.5	2.5
SANDY CLAY w/ COBBLES		2.5	4.0	1.5
CLAY LINE		4.0	6.0	2.0
SILTY SAND w/ GRAVEL		6.0	18.0	12.0
SILTY SAND w/ GRAVEL		18.0	27.0	9.0
HYDRIC BROWN CLAY		27.0	33.0	6.0

8. WELL CONSTRUCTION  
Depth Drilled 33.0 Feet Depth Cased 33.0 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
9.0 Inches 9.0 Feet 33.0 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.1250</u>		<u>Sch 40</u>	<u>0.0</u>	<u>18.0</u>

Perforations:  
Type perforation W ACHIVE SLOTTED  
Size perforation 402C  
From 33.0 feet to 18.0 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 12.0  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 16.0 feet to 33.0 feet

9. WATER LEVEL  
Static water level 20.0 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WOC EXPLOIATION + WELLS  
Contractor  
Address 5700 WASHINGTON WAY  
LAS VEGAS NV 89030  
Nevada contractor's license number 0012952  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 12/12/94

7. WELL TEST DATA  
TEST METHOD:  Bailor  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)  
Date started 12/28 20.0  
10/3 20.0  
Date completed 10/3 20.0