

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27110

1. OWNER Sargent N. Benson ADDRESS AT WELL LOCATION 501 Wally Kayway  
 MAILING ADDRESS 501 Wally Kayway CMW 7 ROAD 4A MOAPA, NV 89025  
MOAPA, NV 89025 Reid Gardner Station

2. LOCATION NE 1/4 SE 1/4 Sec 6 T 15 N OR 6 E Clark County  
 PERMIT NO. 0042-06-701-001 Reid Gardner Station Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand &amp; gravel, trace silt &amp; cobbles (fill)</u>		<u>0</u>	<u>2.5'</u>	<u>2.5'</u>
<u>clay, trace silt (brown)</u>		<u>2.5'</u>	<u>20'</u>	<u>17.5'</u>
<u>silty sand w/ trace clay</u>		<u>20'</u>	<u>22.5'</u>	<u>2.5'</u>
<u>clay w/ trace silty sand</u>		<u>22.5'</u>	<u>31'</u>	<u>8.5'</u>
<u>silty sand w/ trace clay</u>		<u>31'</u>	<u>32'</u>	<u>1'</u>
<u>clay w/ trace silty sand</u>		<u>32'</u>	<u>35'</u>	<u>3'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
9 5/8 Inches 0 Feet 1.5 Feet  
8 1/2 Inches 1.5 Feet 3.5 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 1/2</u>		<u>1/4</u>	<u>0</u>	
<u>2 1/2</u>		<u>1/4</u>	<u>0</u>	

Perforations:  
 Type perforation machine slot  
 Size perforation 1.020  
 From 25-35 feet to 10-15 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 10

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 35-18, 15-9 feet to \_\_\_\_\_ feet

Date started 10/8, 2004  
 Date completed 10/9, 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality poor

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOL Exploration & Wells Contractor  
 Address 1421 S. 39th Ave, Phoenix Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0012852  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2182  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-9-04