

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26435

1. OWNER PATRICK + KAREN KNIPP
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION GRANITE AV. + TETON ST.
SANDY VALLEY NV
CLARK County 088
 2. LOCATION NW 1/4 SW 1/4 Sec. 22 T. 24 N/S R. 56 E
 PERMIT NO. 200-22-301-013 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	5	5
CLAY		5	28	23
CALICHE		28	32	4
CLAY		32	54	22
CALICHE		54	60	6
CLAY		60	72	12
CALICHE		72	77	5
CLAY		77	96	19
CALICHE	W.B	96	102	6
CLAY + GRAVEL		102	124	22
CEMENTED ROCK + GRAVEL	W.B	124	140	16

DGNR/DWR
 RECEIVED
 SEP 20 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1/2 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 92 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. Box 3505 Pahrump Contractor
NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Annie Brown
 By driller performing actual drilling on site or contractor
 Date 8-30-2004

Date started 8-16, 2004
 Date completed 8-23, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)