

Well #1 of 2

well B

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 94310
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26794

1. OWNER BRC ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 875 W WARM SPRINGS Henderson NV 89015
2. LOCATION SE 1/4 SE 1/4 Sec 31 T 21 N 63 E Clark County
PERMIT NO. 16031501002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Seam

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	26	26
Sandy silt		26	66	40
Silt		66	70	4
Silt silt		70	115	45
Silty clay		115	120	5
Sandy silt		120	125	5
Silt		125	180	55
Silty clay		180	190	10
Silt		190	266	76

8. WELL CONSTRUCTION
Depth Drilled 266 Feet Depth Cased 82 Feet
HOLE DIAMETER (BIT SIZE)
From 8 1/2 Inches To 0 Feet 266 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>Sch 80 PVC</u>		<u>0</u>	<u>67</u>

Perforations:
Type perforation Slotted PVC
Size perforation 1.012
From 67 feet to 82 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 59 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 65 feet to 82 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 6-30-04, 20 ____
Date completed 7-2-04, 20 ____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Prosonic Corp Contractor
Address 419 E. JUANITA #104 Mesa AZ 85204 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0051765
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed Alan Winter
By driller performing actual drilling on site or contractor
Date 7-12-04