

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26496

1. OWNER BR C ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 775 W Wynn Springs Rd Henderson NV 89015 _____
2. LOCATION SW 1/4 NW 1/4 Sec 7 T 22 NR 63 E Clark County
PERMIT NO. 17907201007 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other SPICE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	27	27
Sandy silt		27	79	52
Clayey silt		79	99	20
Sandy silt		99	161	62
Clayey silt		161	181	20
Sandy silt		181	203	22
Clayey sand		203	217	14
Clayey silt		217	263	46
Sandy silt		263	402	39

8. WELL CONSTRUCTION
Depth Drilled 402 Feet Depth Cased 382 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 402 Feet
Inches 8 1/2 Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch 80	PVC	0	362

Perforations:
Type perforation Slotted PVC
Size perforation 1.010
From 362 feet to 382 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 355 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 357 feet to 382 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 7-12-04, 20_____
Date completed 7-15-04, 20_____
7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PROSONIC CORP Contractor
Address 419 E. JUANITA #104 Contractor
Mesa AZ 85204
Nevada contractor's license number issued by the State Contractor's Board 0051765
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1941
Signed Alfred Weintz
By driller performing actual drilling on site or contractor
Date 7-16-04

DCNR/DWR
RECEIVED
JUL 22 2004
LAS VEGAS OFFICE

27
A