

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25520

1. OWNER CASTRO SORENSEN ADDRESS AT WELL LOCATION Dyer, NV
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 9 T. 35 N/S R. 35 E Esmeralda County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>sandy, Boulder cl, Dg</u>		<u>0</u>	<u>90</u>	<u>90</u>
<u>Dg + cobbles</u>		<u>90</u>	<u>140</u>	
<u>Clay + Dg</u>		<u>140</u>	<u>165</u>	
<u>Sandy Clay</u>		<u>165</u>	<u>215</u>	

DCNFD/WMB
 RECEIVED
 AUG 02 2004
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 215 Feet Depth Cased 215 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
8 1/4 Inches 50 Feet 215 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 1/8</u>	<u>13</u>	<u>1 5/8</u>	<u>4</u>	<u>14</u>
<u>6</u>		<u>SDR 21</u>	<u>14</u>	<u>215</u>

Perforations:
 Type perforation juv
 Size perforation 5 1/8
 From _____ feet to _____ feet
 From 125 feet to 215 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 215 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 61.7 °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Loach Drilling Inc Contractor
 Address pp box 099 Contractor
Silver Springs NV
 Nevada contractor's license number issued by the State Contractor's Board 31841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-16-04

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>157</u>	<u>200</u>	<u>2 Hr.</u>

Date started 7-11- 20____
 Date completed 7-16-04 20____