WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94325
Permit No.
Basin 170

NOTICE OF INTENT NO. 25138

1. OWNER Jorge Arnu
MAILING ADDRESS 11146 Alora St
Las Vegas NV 89141

ADDRESS AT WELL LOCATION Corner of Coyote LN & Rachel rd. Rachel NV.

2. LOCATION N/N ¼ S/E ¼ Sec. 35 T. 3 N/S R. 55 E Lincoln County
PERMIT NO. (Issued by Water Resources) 010-163-05 (Parcel No.) Sunrise Acres (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	9	9
gravel - sand		9	62	53
Hard Rock		62	71	9
gravel - sand - Boulders	X	71	94	23
Hard Rock		94	99	5
sand gravel - Boulders	X	99	164	65
Clay		164	170	6

DCNR/DWR
RECEIVED
OCT 20 2004
LAS VEGAS OFFICE

Date started 10-9-04, 19
Date completed 10-11-04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
55		3

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	170 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		Sch 40	0	170

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 6"
From 60 feet to 80 feet
From 100 feet to 120 feet
From 140 feet to 170 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling & Pumps (Contractor)
Address HC 61 Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed (By driller performing actual drilling on site or contractor)
Date 10-14-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627