WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94327
Permit No. 71223 T
Basin 219

NOTICE OF INTENT NO. 25134

1. OWNER: JD Davis Family Trust
MAILING ADDRESS: 2201 E Bonanza Las Vegas NV 89101
ADDRESS AT WELL LOCATION: 3335 Warm Springs Road Moapa NV 89025

2. LOCATION: N/E ¼ N/E ¼ Sec. 22 T. 14 N/S R. 65 E. Clark County
PERMIT NO. 71223-T (Issued by Water Resources) 026-22-501-008 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Hard Rock		4	27	23
Clay-Boulders		27	60	33
Clay		60	168	108
Clay-sand	X	168	170	2
Clay		170	189	19
Clay-sand	X	189	193	4
Clay		193	212	19
Sand-Gravel-clay	X	212	215	3
Clay		215	242	27
Sandy clay		242	274	32
Clay		274	281	7
White Chalky Rock		281	327	46
Fractured Rock	X	327	347	20
Hard Rock		347	373	26
gravel-Boulders	X	373	381	8
Hard Rock		381	390	9

DCNR/DWR
RECEIVED
JUL 2 C 2004
LAS VEGAS OFFICE

Date started 6-17-04, 19
Date completed 7-2-04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		6

8. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17½	Inches	0	Feet	110	Feet
12¼	Inches	110	Feet	390	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	390

Perforations:
Type perforation: Factory
Size perforation: 1/8" x 3"
From 130 feet to 150 feet
From 190 feet to 210 feet
From 250 feet to 270 feet
From 290 feet to 310 feet
From 350 feet to 390 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 110'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 110 feet to 390 feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Davis Drilling
Address (Contractor): HC 61 Box 54 Hiko NV 89017

Nevada contractor's license number issued by the State Contractor's Board: 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1181
Signed: Mike Dao (By driller performing actual drilling on site or contractor)
Date: 7-3-04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627