WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94335
Permit No.
Basin 162

NOTICE OF INTENT NO. 27245

1. OWNER JOSE MORALES
MAILING ADDRESS 2471 MORALES LN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2471 MORALES LN

2. LOCATION NW 1/4 SE 1/4 Sec. 34 T 19 N/S R 53 E NYE County
PERMIT NO. Issued by Water Resources | 27-401-11 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| GRAVEL & SAND | | 0 | 65 | 65 |
| CLAY & GRAVEL | | 65 | 160 | 95 |
| GRAVEL | WB | 160 | 167 | 7 |
| CLAY & GRAVEL | | 167 | 210 | 43 |
| GRAVEL | WB | 210 | 260 | 50 |

DCNR/DWR
RECEIVED
OCT 27 2004
LAS VEGAS OFFICE

Date started 10/14/2004, 19__
Date completed 10/15/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10.25 | Inches | 0 | Feet | 260 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 3.63 | .250 | 0 | 260 |
| | | | | |
| | | | | |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 200 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 260 feet to 260 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem (By driller performing actual drilling on-site or contractor)
Date 10/21/04

USE ADDITIONAL SHEETS IF NECESSARY