WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94343
Permit No.
Basin 212

NOTICE OF INTENT NO. 22192

1. OWNER American Pacific Corporation
MAILING ADDRESS 3770 Howard Hughes Parkway Suite 300 Las Vegas Nevada 89109
ADDRESS AT WELL LOCATION Over-flow Parking lot between Wiessner way and Broadbeat

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 21 N/S R. 62 E. Clark County
PERMIT NO. Issued by Water Resources
161-35-501-002 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty Sand | | 0' | 7' | 7' |
| Caliche | | 7' | 10' | 3' |
| Clay Sand Silts | 10.15 | 10' | 70' | 60' |

DCNR/DWR
RECEIVED
SEP 1 2004
LAS VEGAS OFFICE

Date started 8-25-2004, 19
Date completed 8-26-2004, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 70' Feet Depth Cased 18' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6" Inches | 0' Feet | 70' Feet |
| 8" Inches | 0' Feet | 26' Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | 2.06 | 0.474 | 0' | 18' |
| | | | | |

Perforations:
Type perforation Slotted
Size perforation .020
From 18' feet to 13' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 12'
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentinite Chips and Grout
Gravel Packed: ☒ Yes ☐ No
From 20' feet to 12' feet

9. WATER LEVEL
Static water level 10.15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Henry Bailey Boart Longyear (Contractor)
Address 7773 W Seldon lane Peoria AZ 85345 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 16157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-20712
Signed Henry Bailey (By driller performing actual drilling on site or contractor)
Date 9-7-2004

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627