WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94364
Permit No.
Basin 212

NOTICE OF INTENT NO. 25852

1. OWNER Community Bank of Nevada
MAILING ADDRESS 7676 W. Lake Mead Blvd Las Vegas, NV 89129
ADDRESS AT WELL LOCATION 4985 East Desert Inn Rd.

2. LOCATION NE ¼ NE ¼ Sec. 17 T 21 S R 62 E CLARK County
PERMIT NO. na (Issued by Water Resources) | Parcel No. 161-17-501-006 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG "MW-2"

Material	Water Strata	From	To	Thickness
Well casing/screen plugged with sodium bentonite pellets to 8 feet below surface. Remainder of casing plugged with concrete slurry to ground surface.				

DCNR/DWR
RECEIVED
SEP 1 2004
LAS VEGAS OFFICE

Date started September 14, 2004
Date completed " " , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 25' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	25

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 14.78' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Allen c/o Terracon Contractor
Address 4343 S. Polaris Ave Contractor
Las Vegas, NV 89107
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2155
Signed Tim Allen By driller performing actual drilling on site or contractor
Date 9/14/04

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

94364

FIGURE 1 – SITE DIAGRAM



DCNR/DWR
RECEIVED
SEP 1 - 2004
LAS VEGAS OFFICE

Subject Site - Red Outline
North to top of page

Terracon
Project No. 64047782