

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94418
 Permit No. _____
 Basin 21a
 NOTICE OF INTENT NO. 26603

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER TURNBERRY PAVILION PARTNERS LP ADDRESS AT WELL LOCATION 2777 PARADISE RD.
 MAILING ADDRESS 19501 BISCAYNE BLVD. #400 LAS VEGAS, NV
AVENTURA, FL 33180-2377

2. LOCATION SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 09 T 21 S R 61 E CLARK County

PERMIT NO. 162-09-602-011 TURNBERRY TOWER 4
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewater

4. PROPOSED USE Dewater
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
7-40' dewater well				
Fill		0	2'	
Caliche		2	4	
Clay silt, brown dry		4	6	
Clay sand & gravel		6	12	
Brown clay		12	17	
Brown clay sand w/ gravel		17	19	
Caliche		19	25	
Clay, sand & gravel		25	35	
Sandy silt		35	40'	

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	1.250	0	40

Perforations:
 Type perforation Machine
 Size perforation 1/4" x 2.5 x 3 rows @ 13
 From 10 feet to 40 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/14, 20 04
 Date completed 10/19, 20 04

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC. (CONTRACTOR)
 Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/28/04

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

COPIES RECEIVED
 NOV 15 2004
 LAS VEGAS OFFICE