

OFFICE USE ONLY  
Log No. 94432  
Permit No. \_\_\_\_\_  
Basin 105  
52864

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52864

1. OWNER John Feut Coast ADDRESS AT WELL LOCATION 1134 JO LANE  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 NE 1/4 Sec 12 T 12 N/S R 20 E Douglas County  
PERMIT NO. 1220-12-11-002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DIRT-ROCK</u>		<u>0</u>	<u>43</u>	<u>43</u>
<u>GRAY CLAY-GRAVEL</u>		<u>43</u>	<u>54</u>	<u>11</u>
<u>COBBLES</u>	<u>X</u>	<u>54</u>	<u>84</u>	<u>30</u>
<u>BROWN CLAY-ROCK</u>		<u>84</u>	<u>156</u>	<u>72</u>
<u>MEDIUM-FINE GRAVEL</u>	<u>X</u>	<u>156</u>	<u>205</u>	<u>49</u>

8. WELL CONSTRUCTION  
Depth Drilled 205 Feet Depth Cased 205 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
11 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 205 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>71</u>	<u>5</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR 21</u>	<u>5</u>	<u>205</u>

Perforations:  
Type perforation GRINDER CUT  
Size perforation .045" x 4"  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 165 feet to 205 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50 ft  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 50 feet to 205 feet

9. WATER LEVEL  
Static water level 78 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO. INC.  
Address PO Box 1255  
Carson City, NV 89702  
Nevada contractor's license number 46498  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
Signed Jack Dotson  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

Date started 14 Aug 2004  
Date completed 16 Aug 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>1.0</u>

RECEIVED  
04 SEP 14 PM 3:04  
STATE ENGINEERING OFFICE