

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

1. OWNER **Sally Lifo**
MAILING ADDRESS **4200 Old 395**
Carson City

ADDRESS AT WELL LOCATION

~~4200 Old 395~~
3669 Silverado

2. Location **NE 1/4 SW 1/4 Sec 6 T 14N R 20E**
PERMIT NO. **PARCEL NO. 1420-06-301-009**

Douglas County

SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand.		0	55	55
Sand & clay.		55	100	45
Sand.		100	125	25
Big sand.		125	160	35

8. WELL CONSTRUCTION

Depth Drilled	160 feet	Depth Cased	160 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
10 5/8 inches	0 feet	60 feet	60 feet
8 3/4 inches	60 feet	160 feet	160 feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	160

Perforations:

Type Perforation	Factory
Size perforation	3/32 x 3"
From	140 feet to 160 feet
From	feet to feet
From	feet to feet
From	feet to feet
From	feet to feet

Surface Seal YES No Seal Type: Neat Cement

Depth of Seal **50** feet Pumped Cement Grout

Gravel Packed: Yes No Poured Concrete Grout

From **50** feet to **160** feet

RECEIVED
04 SEP 16 AM 11:05
STATE ENGINEERS OFFICE

Date started **8-28 -04**
Date completed **8-31 -04**

7. WELL TEST DATA


TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
5	20			
50	40			
60	60	2		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
NV Driller's Lic (on site) **2275**

Signed 

By driller performing actual drilling on site or contractor

Date **9-9 -04**