WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94438
Permit No.
Basin 105

NOTICE OF INTENT NO. 52177

1. OWNER Michael & Katie Dillon
MAILING ADDRESS 1670 Coyote Rd.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1670 Coyote Rd.
Gardnerville

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T 13N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1320-26-0029-011 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown coarse sand some rock & clay		0	20	20
Brown coarse sand some gravel		20	35	15
Peagravel & coarse sand		35	75	40
Brown sandy clay		75	95	20
Brown sand layers clay	x	95	225	130
Brown coarse sand some gravel	x	225	235	10
Brown coarse sand rock	x	235	280	45

RECEIVED 04 SEP 16 AM 11:03 STATE ENGINEER'S OFFICE

Date started 8/31/2004, 19__
Date completed 9/1/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75		3

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	0	Feet	280	Feet
	inches		Feet		Feet
	inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	280

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 220 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 56
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 56 feet to 280 feet

9. WATER LEVEL
Static water level 109 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/14/2004

USE ADDITIONAL SHEETS IF NECESSARY