WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94439
Permit No.
Basin D5

NOTICE OF INTENT NO. 52227

1. OWNER Jeanne Hendrix
MAILING ADDRESS 1678 Hwy 395 N. # 12
Minden, NV 89423

ADDRESS AT WELL LOCATION 1395 Hawkins Peak Ct.
Gardnerville

2. LOCATION NE 1/4 NE 1/4 Sec. 1 T 12N N/S R 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 1220-01-001-031 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand & gravel		0	85	85
Brown clay		85	113	28
Sand & gravel		113	125	12
Gray coarse sand some gravel		125	170	45
Brown & gray clay		170	195	25
Gray clay		195	235	40
Gray sand coarse	x	235	375	140
Gray clay some coarse sand		375	435	60
Gray clay some sand	x	435	445	10
Gray coarse sand some clay	x	445	455	10
Coarse sand some rock	x	455	475	20
Gray clay coarse sand		475	495	20
Coarse sand some clay		495	510	15
Coarse sand some rock	x	510	575	65
Coarse sand some clay	x	575	596	21

RECEIVED 04 SEP 16 AM 11:03 STATE ENGINEER'S OFFICE

Date started 8/23/2004, 19__
Date completed 8/30/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150+		3

8. WELL CONSTRUCTION
Depth Drilled 596 Feet Depth Cased 596 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	596	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	596

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 436 feet to 476 feet
From 536 feet to 596 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 76
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 76 feet to 596 feet

9. WATER LEVEL
Static water level 243 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce Mackay (By driller performing actual drilling on-site or contractor)
Date 9/13/2004

USE ADDITIONAL SHEETS IF NECESSARY