WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94440
Permit No.
Basin 104

NOTICE OF INTENT NO. 52191

1. OWNER Keith Kennedy
MAILING ADDRESS 1700 Valley View
Carson, NV 89701

ADDRESS AT WELL LOCATION 1700 Valley View

2. LOCATION NW 1/4 SW 1/4 Sec. 28 T 15N N/S R 20E E Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 010-322-14 Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown coarse & fine sand		0	55	55
Brown coarse sand some gravel		55	115	60
Brown sand some clay		115	135	20
Brown coarse sand some fine sand	x	135	175	40
Gray fine and coarse sand	x	175	195	20
Gray and brown coarse and fine sand	x	195	315	120

RECEIVED 04 SEP 16 AM 11:03 STATE ENGINEER'S OFFICE

Date started 8/18/2004, 19__
Date completed 8/23/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		9.5

8. WELL CONSTRUCTION
Depth Drilled ~~313~~ 315 Feet Depth Cased 313 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 5/8	Inches	50	Feet	313	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	313

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 273 feet to 313 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 313 feet

9. WATER LEVEL
Static water level 134 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8/26/2004

USE ADDITIONAL SHEETS IF NECESSARY