WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7474
Permit No.
Basin 153
Corrected
NOTICE OF INTENT NO. 34267

1. OWNER JOHN WILKER
MAILING ADDRESS P.O. BOX 172
EUREKA, NV 89316

ADDRESS AT WELL LOCATION BLOCK 2, LOT 2 10TH STREET & ROSE

2. LOCATION NE 1/4 SW 1/4 Sec. 18 T 21N N/S R 53E E EUREKA County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL	X	165	195	30
SANDY CLAY	X	195	210	15
CLAY		210	220	10

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 9/15/2004, 19__
Date completed 9/17/2004, 19__

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	25		2HRS

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/4	Inches	165	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		SDR-17	160	220

Perforations:
Type perforation SAW CUT
Size perforation 3/16 X 4
From 160 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 162 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 10/5/2004

USE ADDITIONAL SHEETS IF NECESSARY

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74444
Permit No.
Basin 153

NOTICE OF INTENT NO. 54267

1. OWNER JOHN WILKENS
MAILING ADDRESS HC 66-77
EUREKA, NV 89821

ADDRESS AT WELL LOCATION
BLOCK 2, LOT 2

2. LOCATION NE 1/4 SW 1/4 Sec. ___ T 18 N/S R 21 E 53 EUREKA County
PERMIT NO. ___ Issued by Water Resources | Parcel No. ___ | Subdivision Name ___

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other ___

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		165	195	30
SANDY CLAY		195	210	15
CLAY		210	220	10

Date started 9-15-04, 19__
Date completed 9-17-04, 19__

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	25		2

8. WELL CONSTRUCTION
Depth Drilled 165-220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/4	Inches	~~[illegible]~~	Feet	220	Feet
	Inches	165	Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		SDR-17	160	220

Perforations:
Type perforation SAW CUT
Size perforation 3/16" X 4"
From 160 feet to 220 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☐ No
From ___ feet to ___ feet
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR dba FERTIG DRILLING
Contractor
Address P.O. BOX 525
Contractor
EIKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 9-20-04

USE ADDITIONAL SHEETS IF NECESSARY