

OFFICE USE ONLY  
 Log No. 94447  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53477

1. OWNER James Kozen ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7343 Almaden LN 202 Taylor Creek Rd  
Carlsbad, CA 92009 Minden NV 89423  
 2. LOCATION Nw 1/4 NW 1/4 Sec. 03 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. 1219-03-001-068 Taylor Creek Estates Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D G + Rocks		0	16	16
Granit Boulder		16	19	3
D G + Small Rocks		19	68	49
Granit Soft	water	68	140	72
Granit Hard		140	150	10

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 5.1 Feet  
6 1/8 Inches 5.1 Feet 150 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>0.188</u>	<u>+1</u>	<u>150</u>

Perforations:  
 Type perforation Factory  
 Size perforation 1 1/2" x 3"  
 From 70 feet to 80 feet  
 From 120 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.1  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature 60.1 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Santori Dan Contractor  
 Address PO Box 7119 Contractor  
Gardnerville, NV  
 Nevada contractor's license number issued by the State Contractor's Board 57531  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed George E. Steele  
 By driller or authorized actual drilling on-site of contractor  
 Date \_\_\_\_\_

Date started 5-17, 2004  
 Date completed 5-27, 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>10+</u>	<u>8</u>	<u>2</u>

RECEIVED  
 04 JUL 24 AM 10:59  
 STATE ENGINEERS OFFICE  
 Prepared by well log 12/5/04  
 Plugged by well log 12/5/03  
 OCT 21 2004  
 LAS VEGAS OFFICE