WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94448
Permit No.
Basin 88

NOTICE OF INTENT NO. 54486

1. OWNER Mike & Holly Gregg
MAILING ADDRESS 5345 Wildwood Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 5345 Wildwood Dr.

2. LOCATION NW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
045-552-20 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" x 97' domestic water well by perforating the well from 77' to about 14' where we hit a sanitary seal. We pumped approximately 1.5 cu. yards of neat cement from bottom of the well to top using tremie pipe and grout pumper. We cut the top two feet off of the well.				
Washoe Co. Permit #WL040174				

04 AUG 26 AM 11:02
RECEIVED
STATE ENGINEER'S OFFICE

DCNR/DWR
RECEIVED
OCT 21 2004
LAS VEGAS OFFICE

Date started 8/13/2004 , 19__
Date completed 8/13/2004 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 97 Feet Depth Cased 97 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	97

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 77 feet to 14 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 8/16/2004

USE ADDITIONAL SHEETS IF NECESSARY