COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94465
Permit No.
Basin 104

NOTICE OF INTENT NO. 48677

1. OWNER MELVIN RODELA
MAILING ADDRESS POBOX 3135
CARSON CITY, NV 89702

ADDRESS AT WELL LOCATION 812 JENNA CRT
CARSON CITY, NV 89701

2. LOCATION NW ¼ SE ¼ Sec 5 T 14 N R 20 E CARSON County

PERMIT NO. ~~03858~~ (Issued by Water Resources) | 9-822-27 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D G SAND & BROWN				
CLAY		0	130	130
D G SAND , SMALL				
GRAVEL'S GRAY CLAY		130	160	30
D G SAND SMALL				
GRAVEL'S SOME				
BROWN CLAY		160	200	40

RECEIVED 04 OCT -4 PM 12:12 STATE ENGINEER'S OFFICE

DCNR/DWR RECEIVED DEC 02 2004 LAS VEGAS OFFICE

Date started 09/08 , 20 03
Date completed 09/09 , 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	20-30		3 HRS

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188	+2	160

Perforations:
Type perforation MILL SLOT
Size perforation 3/32"
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL

Static water level feet below land surface
Artesian flow NO G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (CONTRACTOR)
Address PO BOX 2227 (CONTRACTOR)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Monty Logan
By driller performing actual drilling on site or contractor
Date 11/27/03

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com