

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 94468  
 Permit No. \_\_\_\_\_  
 Basin 104  
 NOTICE OF INTENT NO. 48681

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WAYNE LEPIRE DDD  
 MAILING ADDRESS PO BOX 2811  
CARSON CITY, NV 89701  
 ADDRESS AT WELL LOCATION 7552 CENTER DR.  
CARSON CITY, NV 89701

2. LOCATION 56 1/4 Sec 5 T 14 N R 22 E CARSON County  
 PERMIT NO. 009-311-55  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG, BROWN SAND AND CLAY		0	120	
GRAY SAND CLAY		120	130	
BROWN SAND CLAY		130	145	
GRAY SAND CLAY		145	155	
SMALL COBBLES		155	165	
BROKEN VOLCANIC ROCK		165	200	

RECEIVED  
 04 OCT -4 PM 12:12  
 STATE ENGINEERS OFFICE

DCNR/DWR  
 RECEIVED  
 DEC 02 2004

LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+2</u>	<u>160</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3/32"  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Artesian flow NO G.P.M. 30+ P.S.I.  
 Water temperature COLD °F Quality NA

Date started 08/18, 20 03  
 Date completed 08/22, 20 03

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIRLIFT</u>	<u>30+</u>	<u>120</u>	<u>1 HOUR</u>

TEST METHOD:  Bailer  Pump  Air Lift

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA PUMP & DRILLING  
 (CONTRACTOR)  
 Address PO BOX 2227  
 (CONTRACTOR)  
DAYTON, NEVADA 89403  
 Nevada contractor's license number issued by the State Contractor's Board 46357  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed Monty Loper Monty Loper  
 By driller performing actual drilling on site or contractor  
 Date 09/28/03