WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94478
Permit No.
Basin 104

NOTICE OF INTENT NO. 52255

1. OWNER Michele Lee
MAILING ADDRESS 4011 North View Dr.
Carson City, NV 89701

ADDRESS AT WELL LOCATION 4011 North View Dr.

2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
010-183-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6" x 162' well by perforating with mills knife from 10' to 150' then we pumped 2 cubic yards of neat cement mixed 5.2 gallons of water per sack. We pumped, using tremie pipe, from the bottom to the top of the well. We then cut off the top of the well.				

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 9/24/2004 , 19
Date completed 9/24/2004 , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
04 OCT -4 PM 12:16
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	162

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 10 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2159
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 9/27/2004

USE ADDITIONAL SHEETS IF NECESSARY