WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 944 83
Permit No.
Basin 88

NOTICE OF INTENT NO. 53679

1. OWNER Sidney Hobbs
MAILING ADDRESS 15425 Willowbrook Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 15425 Willowbrook Dr.

2. LOCATION NE 1/4 NW 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
045-533-06 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite mixed rock	x	182	215	33
Gray coarse sand	x	215	300	85
Gray coarse sand mixed boulders	x	300	375	75

Washoe County Well Permit # WL 040233

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 9/16/2004 , 19__
Date completed 9/19/2004 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		3

STATE ENGINEERS OFFICE
04 OCT -4 PM 12:15
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	182	Feet	375	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	155	375

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 335 feet to 375 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 9/20/2004

USE ADDITIONAL SHEETS IF NECESSARY