WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94488
Permit No.
Basin 88

NOTICE OF INTENT NO. 51688

1. OWNER Jim LeMon
MAILING ADDRESS 15325 Callahan Ranch Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 15325 Callahan Ranch Rd.

2. LOCATION NW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
045-542-12 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

6. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" x 138' domestic water well by perforating from 120' to surface at 1 foot intervals and four around. We then pumped approximately 1.75 cu. yards of neat cement mixed 5.2 gal/sack from the bottom to the top using tremie pipe.				
We cut the top of the well below grade.				
Washoe Co. Permit #WL040235				

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 10/21/2004 , 19__
Date completed 10/21/2004 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	138

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 120 feet to Surface feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 138
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 10/22/2004

USE ADDITIONAL SHEETS IF NECESSARY