WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94492
Permit No.
Basin 104

NOTICE OF INTENT NO. 53691

1. OWNER Tom Fulwider
MAILING ADDRESS 4249 Kings Canyon Rd.
Carson City, NV 89703

ADDRESS AT WELL LOCATION 4249 Kings Canyon

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T 15N N/S R 19E E Carson County
PERMIT NO. _____ Issued by Water Resources | 007-072-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill sand and rust		130	145	15
Gravel and sand small boulders		145	200	55
Brown sandy clays with volcanic gravels		200	280	80
Gray sandy clays with volcanic gravels		280	300	20
Gray clay		300	302	2
Gray granite		302	310	8
Gray to pink granite		310	420	110
Soft zone	x	420	421	1
Gray to pink granite		421	452	31

RECEIVED
04 OCT 25 PM 3:12
STATE ENGINEERS OFFICE

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 9/24/2004, 19__
Date completed 10/5/2004, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7		3

8. WELL CONSTRUCTION

Depth Drilled 452 Feet Depth Cased 452 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	130	Feet	452	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	+2	130
6 5/8	12.92	.188	0	297
5	10.79	.188	289	452

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

From	137	feet to	157	feet
From	177	feet to	197	feet
From	217	feet to	237	feet
From	257	feet to	277	feet
From	412	feet to	452	feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 10/6/2004

USE ADDITIONAL SHEETS IF NECESSARY