WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94483
Permit No.
Basin 104

NOTICE OF INTENT NO. ~~45802~~/49557

1. OWNER Phillip Harrison
MAILING ADDRESS 2249 South Edmonds Drive
Carson City, NV 89701

ADDRESS AT WELL LOCATION 2249 South Edmonds Drive, Carson City, NV.

2. LOCATION NE 1/4 SW 1/4 Sec. 21 T 15N20E N/S R 20E E Carson City County
PERMIT NO. n/a (Issued by Water Resources) 010-062-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 95' of 1" drop pipe with pump. Measured static water level at 82' and depth of well at 97'. Bailed debris from well to depth of 101' where we hit hard bottom. Installed Mills Knife and perforated 8" casing from 60' back to 10' where we could not cut casing due to possible cement seal. We cut in 4 rows per foot. We removed perforator and installed 95' of 2" tremme pipe. We then mixed 48 bags of Portland cement with approximately 250 gallons of water and pumped cement from bottom of well to surface. Volume of well should have required 1.3 yards but actually used 1.75 yards. Measured cement in well the following day and it was 2' below ground surface. Cut off casing at this depth.				

RECEIVED OCT 25 2004 STATE ENGINEER'S OFFICE

DCNR/DWR RECEIVED DEC 0 2 2004 LAS VEGAS OFFICE

Date started 10/12/2004, 19__
Date completed 10/12/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled n/a Feet Depth Cased 101' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188"	+2	101'

Perforations:
Type perforation Mills Knife
Size perforation
From 60' feet to 10' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 101'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 82' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Franzen (By driller performing actual drilling on-site or contractor)
Date 10/21/2004

USE ADDITIONAL SHEETS IF NECESSARY