WASHOE # WL40183

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 94498
Permit No.
Basin 91A

NOTICE OF INTENT NO 53151

1. OWNER **Larry Erwin** ADDRESS AT WELL LOCATION **10265 Pathfinder Dr**
MAILING ADDRESS **10265 Pathfinder Dr**
Reno NV

2. Location **SW** 1/4 **NW** 1/4 Sec **13** T **21N** R **18E** **Washoe** County
PERMIT NO. PARCEL NO. **087-050-14** SUBDIVISION NAME

3. WORK PERFORMED
x New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
x Air | Other | Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay.		**0**	**8**	**8**
				0
Sand.		**8**	**23**	**15**
				0
DG & clay.		**23**	**297**	**274**
				0
DG		**297**	**316**	**19**
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

RECEIVED
04 OCT 26 AM 11:42
STATE ENGINEERS OFFICE

DCNR/DWR
RECEIVED
DEC 8 2004
LAS VEGAS OFFICE

Date started **9-24** -04
Date completed **9-27** -04

7. WELL TEST DATA
TEST METHOD: Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
10	15	
30	**40**	
40	65	
50	106	

8. WELL CONSTRUCTION
Depth Drilled **316** feet Depth Cased **316** feet
HOLE DIAMETER (BIT SIZE)

		From		To	
11	inches	**0**	feet	**50**	feet
8 3/4	inches	**50**	feet	**316**	feet
	inches		feet		feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	**12.94**	**188**	**+1 1/2**	**316**

Perforations::
Type Perforation **Factory**
Size perforation **3/32 x 3"**
From **296** feet to **316** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal **X** YES No
Depth of Seal **50** feet
Pumped
x Poured

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

Gravel Packed: X Yes No
From **50** feet to **316** feet

9 WATER LEVEL
Static water leve **210** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 10-1 -04