

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53497

1. OWNER Sunshine Construction ADDRESS AT WELL LOCATION 548 Jackson Ranch Rd
 MAILING ADDRESS PO Box 1538 Gardnerville NV 89460
Minden NV 89423
 2. LOCATION NW 1/4 SE 1/4 Sec 26 T 12 N/S R 19 E DOUGLAS County
 PERMIT NO. 1219-26-001-048 Jackson Ranch Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>D.G.</u>		<u>0</u>	<u>122</u>	<u>122</u>
<u>D.G. w/ small rocks</u>		<u>122</u>	<u>130</u>	<u>8</u>
<u>D.G.</u>		<u>130</u>	<u>188</u>	<u>58</u>
<u>Granite</u>		<u>188</u>	<u>200</u>	<u>12</u>

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
<u>8 3/4</u> Inches	<u>100</u> Feet	<u>200</u> Feet
<u>12 1/4</u> Inches	<u>0</u> Feet	<u>100</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 2 1/2"
 From 110 feet to 135 feet
 From 175 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature 60.1 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ground Ponders Well Drilling Contractor
 Address PO Box 7119 Contractor
Gardnerville NV 89460
 Nevada contractor's license number issued by the State Contractor's Board 0057531
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 14652
 Signed George E. Steele
 By driller performing actual drilling on site or contractor
 Date 24/sep/04

Date started 9-11, 2004
 Date completed 9-14, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 04 SEP 28 AM 10:25
 STATE ENGINEERS OFFICE

DCNR/DWR
 RECEIVED
 DEC 02 2004

LAS VEGAS OFFICE