WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94506
Permit No.
Basin 105

NOTICE OF INTENT NO. 53486

1. OWNER Julie Shoush
MAILING ADDRESS 1630 Chowbuck St
Minden NV 89423

ADDRESS AT WELL LOCATION 1630 Chowbuck St
Minden NV 89423

2. LOCATION N.~~W.~~ ¼ NW ¼ Sec. 35 T 14 N/S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 1420 35 101040 (Parcel No.) Johnson Lane (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand + Gravel	✓	305	323	18
Clay Brown		323	362	39
Gravel, Coarse	✓	362	367	5
Clay, Brown		367	405	38
Small, Gravel, Stringers	✓	405	421	16
Clay, Grey		421	478	57
Granite	✓	478	500	22

RECEIVED
04 SEP 28 AM 10:25
STATE ENGINEERS OFFICE

DCNR/DWR
RECEIVED
DEC 0 2 2004
LAS VEGAS OFFICE

Date started 8-5, 20 04
Date completed 9-9, 20 04

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	32	43	3

8. WELL CONSTRUCTION
Depth Drilled ~~195~~ 500 Feet Depth Cased ~~327~~ 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6½"	Inches	305 Feet	500 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16		.188		

Perforations:
Type perforation Factory
Size perforation 3/32" x 2.5"
From 294 feet to 314 feet
From 356 feet to 376 feet
From 397 feet to 417 feet
From 480 feet to 500 feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 176 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ground pounders Well Drilling (Contractor)
Address PO Box 7119 G-Ville NV 89460 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0057521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed George E. Stab (By driller performing actual drilling on behalf of contractor)
Date 9/14/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627