

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49265

1. OWNER MICHAEL THYSE ADDRESS AT WELL LOCATION 11875 HEARTPINE ST  
 MAILING ADDRESS 11875 HEARTPINE ST RENO, NV. 89506  
 2. LOCATION SW 1/4 NW 1/4 Sec 15 T 21 N/S R 19 E WASHOE County  
 PERMIT NO. 080-353-04 LEMMON VALLEY Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness	
HARD GRANITE		205	200	205	5
SOFT GRANITE			205	235	30
HARD GRANITE			235	248	13
SOFT GRANITE			248	274	26
HARD GRANITE			274	279	5
SOFT GRANITE			279	282	3
HARD GRANITE			282	289	7
SOFT GRANITE			289	295	6

8. WELL CONSTRUCTION  
 Depth Drilled 295 Feet Depth Cased 295 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches 200 Feet 295 Feet  
 To \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2	PVC	SDR/21/F480	115	295

 Perforations:  
 Type perforation FACTORY SCREEN  
 Size perforation 3 X .032  
 From 255 feet to 295 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 9. WATER LEVEL  
 Static water level 199 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD°F Quality GOOD

Date started 9-2-2004 20.04  
 Date completed 10-16-2004 20.04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
10-17-2004	12	48	8

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WILLIAM GEORGE MOSEGAARD Contractor  
 Address 7900 N Virginia St. #21 Contractor  
RENO NV 89506  
 Nevada contractor's license number issued by the State Contractor's Board 53579  
 Nevada's license number issued by the Division of Water Resources, the on-site driller 2211  
 Signed William George Mosegaard  
 By driller performing actual drilling on site or contractor  
 Date 10-18-2004

RECEIVED  
 04 OCT 20 AM 10:50  
 STATE ENGINEERS OFFICE

DGNR/DWR  
 RECEIVED

DEC 02 2004

LAS VEGAS OFFICE