

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94551
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 27253

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SHEA ANDERSON
 MAILING ADDRESS 3300 S. PRARIE
PAHRUMP, NV

ADDRESS AT WELL LOCATION 3300 S. PRARIE

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T 20
 PERMIT NO. 40-664-06
Issued by Water Resources Parcel No.

N/S R 53 E NYE County
CALVADA VALLEY UNIT 4A
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	15	15
CALICHE		15	26	11
CLAY		26	41	15
CALICHE		41	56	15
CLAY		56	75	19
CALICHE	WB	75	84	9
CLAY		84	115	31
CALICHE	WB	115	128	13
CLAY		128	139	11
CALICHE	WB	139	150	11
CLAY		150	163	13
CALICHE		163	175	12
CLAY		175	180	5

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>.363</u>	<u>.250</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 110 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 11/23/04

Date started 11/17/2004, 19____
 Date completed 11/17/2004, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

DCNR/DWR
 RECEIVED
 DEC 02 2004
 LAS VEGAS OFFICE