

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48958

1. OWNER Fred + Patricia Shvale ADDRESS AT WELL LOCATION 249 West View Road Smith Nev. 89430  
 MAILING ADDRESS P.O. Box 16 Smith Nevada 89430  
 2. LOCATION SE 1/4 SW 1/4 Sec. 13 T. 11 N/S, R. 23 E. Lyon County  
 PERMIT NO. SE 1010-321-26-010 Parcel No. 19-211-05 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand fine</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>brown clay</u>		<u>30</u>	<u>57</u>	<u>27</u>
<u>sand fine + coarse</u>		<u>57</u>	<u>95</u>	<u>38</u>
<u>pea gravel</u>		<u>95</u>	<u>107</u>	<u>12</u>
<u>hard &amp; green clay</u>		<u>107</u>	<u>136</u>	<u>29</u>
		<u>136</u>	<u>140</u>	<u>4</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 Inches From 0 Feet To 50 Feet  
6 Inches From 50 Feet To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1 8/8</u>	<u>0</u>	<u>140</u>

 Perforations:  
 Type perforation factory saw slott  
 Size perforation 50 thousand x 3  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Oct 9, 2004  
 Date completed Oct 12, 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>28</u>	<u>5 ft.</u>	<u>3 hrs</u>

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Mills Drilling Contractor  
 Address P.O. Box 92 Smith Nev. 89430 Contractor  
 Nevada contractor's license number 32166 A issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Mills By driller performing actual drilling on site or contractor  
 Date Oct 14-04