

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94612
 Permit No. _____
 Basin 101
 NOTICE OF INTENT NO. 52900

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **CHRH**
 MAILING ADDRESS P.O. Box 5010
Fallon, N V 89406
 ADDRESS AT WELL LOCATION **CHRH**
733 Hunterparkway
Fallon, NV 89406

2. LOCATION nw 1/4 nw 1/4 Sec 30 T 19 N R 29 E **churchill** County
 PERMIT NO. 008-314-07
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	6	6
Brown Clay		6	12	4
Brown Sand/Gravel		12	23	11
Brown Clay		23	28	5
Gray Clay		28	34	6
Blue Green Clay		34	39	5
Black Sand		39	50	11
Black Clay		50	52	2
Black Green Clay		52	58	6
Black & White Gravel		58	76	18
Brown Clay		76	82	6
Brown Gravel		82	98	16
Gray Clay		98	132	34
Black/Gray Clay		132	147	15
Black Clay		147	152	5
Black & White Gravel		152	156	4
Gray Clay		156	168	12
Black Sand		168	170	2
Black Gray Clay		170	178	8
Black Sand		178	180	2
Gray Clay		180	210	30
Brown Sand/Gravel	XX	210	212	2

8. WELL CONSTRUCTION
 Depth Drilled 212 Feet Depth Cased 212 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ 0 Feet _____ 212 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	212

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From _____ 207 feet to _____ 212 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ 100 feet to _____ 212 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling Inc (CONTRACTOR)
 Address PO. Box 1265 (CONTRACTOR)
Fallon, NV 89407

Date started 06/07/2004
 Date completed 06/07/2004

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>20</u>			
Draw Down (Feet Below Static)			
<u>1hr</u>			
Time (Hours)			

Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 7/16/04

RECEIVED
 04 JUL 23 AM 0:58
 STATE ENGINEERS OFFICE