COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94616
Permit No.
Basin 101

NOTICE OF INTENT NO. 54570

1. OWNER Frank Woolsey
MAILING ADDRESS 2171 W Williams PMB 280
Fallon, N V 89406

ADDRESS AT WELL LOCATION Frank Woolsey
4320 Falcon Drive
Fallon, NV 89406

2. LOCATION SW ¼ NW ¼ Sec 28 T 19 N R 28 E churchill County

PERMIT NO. | Issued by Water Resources | 008-282-12 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Gray Clay		10	30	20
Black Gravel		30	34	4
Gray Clay		34	43	9
Blue Clay		43	45	2
Black Gravel		45	54	9
Blue Clay		54	59	6
Brown Gravel	XX	59	63	4

RECEIVED
04 JUL 23 AM 10:58
STATE ENGINEER'S OFFICE

Date started 03/25/ , 20 04
Date completed 03/25/ , 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 63 ~~66~~ Feet Depth Cased 63 ~~66~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	63 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	63

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 60 feet to 63 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 63 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address PO. Box 1265 (CONTRACTOR)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Namon Parsons
By driller performing actual drilling on site or contractor
Date 04/25/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com