

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94662
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27289**

1. OWNER **MEL NORTH** ADDRESS AT WELL LOCATION **1700 GEOFFREY ST**
 MAILING ADDRESS **1700 GEOFFREY ST**
PAHRUMP, NV

2. LOCATION **NE** 1/4 **NW** 1/4 Sec. **32** T **19S** N/S R **53E** E **NYE** County
 PERMIT NO. _____ Parcel No. **41-582-26** **GOLDEN SPRING RANCH UNIT 7** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	64	64
CALICHE	WB	64	72	8
CLAY		72	94	22
CALICHE	WB	94	111	17
CLAY		111	136	25
CALICHE	WB	136	144	8
CLAY		144	162	18
CALICHE	WB	162	173	11
CLAY		173	190	17

8. WELL CONSTRUCTION
 Depth Drilled **190** Feet Depth Cased **190** Feet

HOLE DIAMETER (BIT SIZE)
 From **10.25** Inches To **0** Feet **190** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	.363	.250	0	190

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**

From **130** feet to **190** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **190** feet

9. WATER LEVEL
 Static water level **52** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F. Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **P.O. BOX 4220** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed _____ By driller performing actual drilling on-site or contractor
 Date **12/9/04**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
 RECEIVED
 DEC 22 2004
 LAS VEGAS OFFICE

Date started **12/8/2004**
 Date completed **12/1/1004**