

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94663
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27306

1. OWNER CRAIG GUGINO ADDRESS AT WELL LOCATION 1800 W. GEORGENE ST
 MAILING ADDRESS 1800 W. GEORGENE ST
PAHRUMP, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 32 T 19S N/S R 53E E NYE County
 PERMIT NO. 41-583-23 GOLDEN SPRING RANCH #7
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	62	62
CALICHE	WB	62	68	6
CLAY		68	84	16
CALICHE	WB	84	98	14
CLAY		98	123	25
CALICHE	WB	123	134	11
CLAY		134	162	28
CALICHE	WB	162	174	12
CLAY		174	190	16
CALICHE	WB	190	210	20

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 210 Feet
10.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>210</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 150 feet to 210 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 210 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F. Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas De...
 By driller performing actual drilling on-site or contractor
 Date 12/9/04

Date started 12/8/2004 19
 Date completed 12/9/2004 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR
 RECEIVED
 DEC 22 2004
 LAS VEGAS OFFICE