

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT


Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. **94731**

Permit No.

Basin **162**



NOTICE OF INTENT NO. **26855**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **Eyserbeck Const.** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **4670 W. Charleston Park**
Pahrump, NV 89060 **4670 W. Charleston Park**

2. LOCATION **S/E** 1/4 **S/W** 1/4 Sec. **14** T **20S** N/S R **52E** E **Nye** County
 PERMIT NO. _____ **41-493-27** **Golden Spring Ranch**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition
 Deepen Abandon Other _____

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------|--------------|-----------|------------|------------|
| brown silt | | 0 | 40 | 40 |
| brown silt with clay | x | 40 | 180 | 120 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

DCNH/DWH RECEIVED
 DEC 03 2004
 LAS VEGAS OFFICE

Date started **10/19/04**, 19
 Date completed **10/19/04**, 19

7. WELL TEST DATA

| TEST METHOD: | Draw Down (Feet Below Static) | | Time (Hours) |
|-----------------------------------|-------------------------------|--|--------------|
| | G.P.M. | | |
| <input type="checkbox"/> Bailer | | | |
| <input type="checkbox"/> Pump | | | |
| <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

8. WELL CONSTRUCTION

Depth Drilled **180** Feet Depth Cased **180+1** Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | To | Feet | Feet |
|-----------|----------|------------|------|------|
| 11 | 0 | 180 | | |
| | | | | |
| | | | | |
| | | | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| 6 5/8 | 3.7 | .280 | 0 | 180 |
| | | | | |
| | | | | |

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **160** feet to **180** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **180** feet

9. WATER LEVEL

Static water level **65** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **5801 S. Homestead** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed _____
 By driller performing actual drilling on-site or contractor **11-30-04**
 Date _____