

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 94749  
 Permit No. \_\_\_\_\_  
 Basin 162

NOTICE OF INTENT NO. 26868

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Johnson Const. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4681 Melissa Lane 4681 Melissa Lane  
Pahrump, NV 89060

2. LOCATION S/E 1/4 S/E 1/4 Sec. 2 T 21S N/S R 53E E Nye County  
 PERMIT NO. 44-842-06 Valley View Estates  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	3	3
grey loam		3	10	7
brown clay		10	18	8
white caleche		18	21	3
See next line		21	65	44
grey loam with caleche strings				
brown loam	x	65	106	41
brown caleche	x	106	109	3
brown loam	x	109	166	57
brown caleche	x	166	174	8
brown loam	x	174	175	1

**DCNR/DWR  
 RECEIVED  
 JAN 07 2005  
 LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled 175 Feet Depth Cased 175+1 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
11 inches 0 Feet 175 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	175

Perforations:  
 Type perforation sawcut  
 Size perforation .188

From 145 feet to 175 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 175 feet

9. WATER LEVEL  
 Static water level 68 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc.  
 Contractor  
 Address 5801 S. Homestead  
 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on-site of contractor  
 Date 1-5-05

Date started 11/30/04 .19  
 Date completed 11/30/04 .19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)