WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94756
Permit No.
Basin 162

NOTICE OF INTENT NO. 27315

1. OWNER RICHARD SAGER
MAILING ADDRESS 5820 E. GRAINMILL RD.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5820 E. GRAINMILL RD

2. LOCATION SE 1/4 NE 1/4 Sec. 16 T 21S N/S R 54E E NYE County
PERMIT NO. (Issued by Water Resources) | Parcel No. 43-121-04 | Subdivision Name COTTONWOODS AT HAFEN RANCH

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & ROCKY		0	23	23
CEMENTED SAND & GRAVEL		23	104	81
SAND & GRAVEL	WB	104	140	36
CLAY & GRAVEL		140	149	9
SAND & GRAVEL	WB	149	160	11
CLAY & GRAVEL		160	170	10
SAND & GRAVEL	WB	170	175	5

DCNR/DWR
RECEIVED
JAN 12 2005
LAS VEGAS OFFICE

Date started 1/3/2005 , 19__
Date completed 1/3/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	175 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	175

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 115 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (by driller performing actual drilling on-site or contractor)
Date 1/3/05

USE ADDITIONAL SHEETS IF NECESSARY