


REPORT NO. **A04.065**

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



LOG NO. **94774**
PERMIT NO. **083**
BASIN _____
NOTICE OF INTENT NO. **52120**

1. OWNER **Brad Shirley** ADDRESS OF WELL **18600 Rocky Rd**
MAILING ADDRESS **9 Dyer Ave. Baytown, Texas 77520** **Virginia Ranches**
2. WELL LOCATION **NW** 1/4 **NW** 1/4 SEC. **2** T **17** R **21** E **Storey** COUNTY
PERMIT NO _____ PARCEL NO **004-281-92** SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt & Boulders		0	4	4
Clay & Rock		4	10	6
Black Rock		10	230	220
Brown & Green Rock		230	270	40
Brown Clay & Volcanic Rock		270	285	15
Gray & Brown Clay		285	290	5
Gray Clay		290	310	20
Clay & Basalts		310	385	75
Green Clay & Brown Basalt		385	410	25
Gray Clay		410	415	5
Black, Gray, Brown & White Clay		415	520	105
Multi Color Clay		520	525	5
Black Rock & Clay		525	545	20
Green Rock, Basalt & Clay		545	560	15
Brown-Clay		560	620	60
Gray Clay & Black Rock	X	620	678	58

8. WELL CONSTRUCTION

Depth Drilled **678** Depth Cased **678**

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches **0** Feet **50** Feet
8 1/2 Inches **50** Feet **678** Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	678

PERFORATIONS:

Type Perforation **FAC SAW** Size Perforation **3/32 X 3**
From **618** Feet to **658** Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:

Seal Depth **50**
 Neat Cement
 Cement Grout
PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED: Yes No

From **50** Feet to **678** Feet

Notes: **UTM:**

0276164
4361339 Elevation: 6047'

Date Started **8/3/04** Date Completed **8/13/04**

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		3Hr.

9. WATER LEVEL

Static Water Level **375** Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**
Address **675 Edison Way**
Reno, NV 89502

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. **15294** ON SITE **1981**

Signed *Rogerenthal*
By driller performing actual drilling on site or contractor

Date **August 13, 2004**