

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50552

1. OWNER Queen Stake Resources USA ADDRESS AT WELL LOCATION Queen Stake  
 MAILING ADDRESS Jerritt Canyon HC-31 Jerritt Canyon East Dash  
Box 78

2. LOCATION SE 1/4 SW 1/4 Sec 8 T 40 S R 54 ELKO County  
 PERMIT NO. Waiver # M/0-1321 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Chert Siltstone		0	85'	
siltstone		85	180'	
Dolomitic Siltstone		180	485'	
Calcareous siltstone		485	680'	
Chert & Limestone		680	765'	
Tan & Gray Limestone		765	810'	
Dark Gray Limestone		810	1045'	
Med. Gray Limestone		1045	1090'	
PLUGGED BY GRW LG #112235 04/21/03 11:26 41.364582°N 115.920876°W NAD 27 (+)				

8. WELL CONSTRUCTION  
 Depth Drilled 1080' Feet Depth Cased 800' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0' To 20' Feet  
8" Inches  
 From 20' To 1080' Feet  
5 3/4" Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/8"</u>	<u>.7</u>	<u>SCH-80 PVC</u>	<u>0'</u>	<u>800'</u>

Perforations:  
 Type perforation Horz. slot  
 Size perforation .080  
 From 800' feet to 400' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 1080' feet to 390' feet

9. WATER LEVEL  
 Static water level 390' feet below land surface  
 Artesian flow NO 75 G.P.M. 360 P.S.I.  
 Water temperature 59° F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ward Weaver - Rimrock Drilling  
 Address 2305 Last Chance Rd.  
ELKO, NV. 89801  
 Nevada contractor's license number 0030630  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676  
 Signed Ward Weaver  
 By driller performing actual drilling on site or contractor  
 Date 8-16-04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			