

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 94780
 Permit No. _____
 Basin 044
 NOTICE OF INTENT NO. **49069**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SYLVIA CALLOWAY
 MAILING ADDRESS P.O. BOX 2448
ELKO, NV 89803

ADDRESS AT WELL LOCATION ADOBE SUMMIT

2. LOCATION SE 1/4 SW 1/4 Sec. 35 T 38N
 PERMIT NO. _____

N/S R 54E E ELKO County

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE
 Domestic
 Irrigation
 Test
 Municipal/Industrial
 Monitor
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SUB SOIL		0	5	5
CONGLOMERATE/CLAY/GRAVEL		5	8	
L			8	3
CLAY GRAVEL		8	52	44
CALICHE CLAY		52	73	21
WHITE SANDSTONE		73	80	7
CLAY/TAN GRAVEL		80	92	12
GRAVEL/WHITE CLAY	X	92	110	18
WHITE SANDSTONE	X	110	185	75

RECEIVED
 04 AUG 20 AM 10:56
 STATE ENGINEERS OFFICE

Date started 7/25/2004 19__
 Date completed 7/27/2004 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
APPROX	35		3HRS

TEST METHOD: Bailer Pump Air Lift

8. WELL CONSTRUCTION

Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
10	0	185	Feet
			Feet
			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Fl. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	25
6	SDR-17	PVC	25	185

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8X3
 From 185 feet to 185 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 52
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No 25-52 Bentonite Grout
 From 52 feet to 185 feet

9. WATER LEVEL

Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING
 Contractor

Address P.O. BOX 525
 Contractor

ELKO, NEVADA 89803

Nevada contractor's license number issued by the State Contractor's Board 031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Sharel C. Fertig Sr.
 By driller performing actual drilling on-site or contractor

Date 8/12/2004