

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49070

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER SYLVIA CALLOWAY  
 MAILING ADDRESS P.O. BOX 2446  
ELKO, NV 89803  
 ADDRESS AT WELL LOCATION ADOBE SUMMIT, ELKO

2. LOCATION SE 1/4 SW 1/4 Sec. 35 T 36N N/S R 54E E ELKO County  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_  
TRACT OF LAND Parcel No. \_\_\_\_\_  
 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUB SOIL		0	3	3
HARDPAN		3	5	2
CEMENTED GRAVEL		5	38	33
FRACTURED		38		
CEMENT/GRAVEL			40	2
CEMENTED GRAVEL		40	50	10
FRACTURED CEMENTED GRAVEL		50		
GRAVEL			80	30
CEMENTED GRAVEL		80	110	30
HARD CEMENT GRAVEL		110	130	20
FRACTURED CEMENTED GRAVEL	X	130		
GRAVEL			175	45
WHITE SANDSTONE	X	175	205	30

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cased 205 Feet  
 HOLE DIAMETER (BIT SIZE)  
 10 Inches From 0 Feet To 205 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	25
6	SDR-17	PVC	25	205

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 1/8X3  
 From 185 feet to 205 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No 25-54 Bentonite Grout  
 From 54 feet to 185 feet

9. WATER LEVEL  
 Static water level 103 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SHAREL C. FERTIG SR. DBA FERTIG DRILLING CO.  
 Contractor  
 Address P.O. BOX 525  
 Contractor  
ELKO, NEVADA 89803  
 Nevada contractor's license number issued by the State Contractor's Board 031904TRG1.BIN  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Sharel C. Fertig  
 By driller performing actual drilling on-site of contractor  
 Date 8/17/2004

Date started 7/27/2004 .19  
 Date completed 7/29/2004 .19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
APPROX	15		3.5

RECEIVED  
 04 AUG 20 AM 10:56  
 STATE ENGINEERS OFFICE