WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 94782
Permit No.
Basin 101

NOTICE OF INTENT NO. ~~53078~~ 53076

1. OWNER DAVID ~~SLAYTON~~ SLATON RC 9-21-04
MAILING ADDRESS 1150 SODA LAKE ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1150 SODA LAKE ROAD

2. LOCATION SW 1/4 SW 1/4 Sec. 21 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources
Parcel No. 008-211-69
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	18	17
BROWN CLAY		18	20	2
BROWN SAND		20	30	10
GRAY CLAY		30	70	40
GRAY CLAY		70	75	5
BROWN SAND	X	75	98	23

Date started 8/12/~~1994~~ 2004, 19__
Date completed 8/12/~~1994~~ 2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

STATE ENGINEERS OFFICE
04 AUG 30 PM 2:26
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 98 Feet Depth Cased 98 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	98	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	98

Perforations:
Type perforation MACHINE PERF
Size perforation .080
From 92 feet to 96 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 30' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed _____ By driller performing actual drilling on-site or contractor
Date 8/26/2004

USE ADDITIONAL SHEETS IF NECESSARY